



COUNTRY REPORT ROMANIA

STUDY ON THE WIND POWER POTENTIAL IN BULGARIA, HUNGARY, AND ROMANIA

Client:

A study conducted on behalf of the European Climate Foundation.

AIT Austrian Institute of Technology GmbH

Gustav Resch, Lukas Liebmann, Ricki Hirner

REKK:

Andras Mezosi, Laszlo Szabo

VIENNA, BUDAPEST, BUCHAREST, 30 NOVEMBER 2023

Study on the wind power potential in Bulgaria, Hungary, and Romania – Country Report Romania

List of Authors:

Gustav Resch, Lukas Liebmann, Ricki Hirner (all AIT)

Andras Mezosi, Laszlo Szabo (all REKK)

This study on the wind power potential in Bulgaria, Hungary, and Romania has been conducted, on behalf of the European Climate Foundation (ECF), by AIT Austrian Institute of Technology GmbH, Center for Energy, Competence Unit Integrated Energy Systems (IES) in close collaboration with REKK – Regional Centre for Energy Policy Analysis as well as with local partners from the study region, including EFdeN – Sustainable and Green Homes from Romania and the Center for the Study of Democracy (CSD) from Bulgaria. The study team gratefully acknowledges the support provided by ECF, specifically by Sorin Cebotari, acting as responsible officer at ECF. A big thanks goes also to various stakeholders consulted during the execution of the study – their constructive feedback helped to reshape the analysis in accordance with country and regional specifics.

Vienna, Budapest, Bucharest, 2023.

Contact point @AIT:

Dr. Gustav Resch, Senior Scientist and Thematic Coordinator
for the Research Field Energy Scenarios and System Planning
at AIT, Center for Energy, Integrated Energy Systems (IES).

Email: gustav.resch@ait.ac.at

CONTENT

Content.....	3
1 Introduction.....	4
1.1 Policy context	4
1.2 Goal of this study	4
1.3 Structure of this report	5
2 Method of approach.....	6
2.1 Task 1: GIS-based analysis of the wind power potential	6
2.1.1 Brief overview on the approach taken	6
2.1.2 Background information and technical details	8
2.2 Task 2: Complementary assessment of electricity market impacts of an enhanced wind deployment.....	10
2.2.1 Modelling approach	10
2.2.2 Scenario set-up.....	10
3 Results of the GIS-based analysis of Wind potentials in Romania.....	12
3.1 Onshore wind potentials	12
3.1.1 Technical potentials at the national level.....	12
3.1.2 Technical potentials at the regional level	14
3.1.3 Mapping with the grid infrastructure	19
3.2 Offshore wind potentials (from a cross-border perspective)	20
3.3 Brief summary of results & comparison with national energy planning	23
3.4 Brief consideration of economics	25
4 Assessment of Electricity Market Impacts of an enhanced Wind Deployment.....	26
4.1 Wholesale electricity prices.....	26
4.2 Wind market value	26
4.3 PV market value	27
4.4 RES curtailment.....	27
4.5 Electricity mix.....	28
4.6 Balancing Reserve capacity mix	29
4.7 CO ₂ emissions	30
5 Concluding remarks.....	31
6 References.....	32

1 INTRODUCTION

1.1 Policy context

Our planet's climate emergency and Russia's war continuing to wage on Ukraine are making it clear that we need to effectively decarbonize the ways we produce and consume energy. The energy sector, including the electricity sector, transport, industry, and heating & cooling, is responsible for around 75% of the EU's Greenhouse Gas (GHG) emissions. This is why EU leaders have agreed on making the continent climate-neutral by mid-century, by substantially reducing the dependency on fossil fuels, with most of it being imported from outside Europe. Today the need to decarbonize is aggravated by severe shortages in energy supply, as well as skyrocketing inflation and energy price levels, threatening the performance of our economies. In parallel, the cost-of-living crisis is substantially reducing purchasing power among EU citizens and exposing especially vulnerable groups to poverty risks.

In this context of a multiple global crisis, the EU is in the process to agree on more ambitious climate and energy target levels, which are being revised and negotiated under the Green Deal and more recently, the REPowerEU initiative. To reduce GHG emission by 55% until 2030, Europe must significantly accelerate the transition to systems that are powered and fuelled by renewable electricity and gases, with EU institutions decide on new targets to increase the share of renewable energy and energy efficiency until 2030. This requires strong commitment among EU and national decision-makers, who are tasked to implement drastic, no-regret, measures and make the profound and systemic transformation of our economies become reality.

Within Europe as well as globally wind and solar energy are acknowledged as the key renewable energy sources for supplying our future demand for energy, done with proven and cost-effective conversion technologies that serve for the provision of electricity. Whilst solar power at small- as well as at utility-scale has increased steadily and widespread across Europe, the picture of wind power development is more diverse and inhomogeneous geographically. In overall terms, at EU level significant progress and a steady growth has been maintained but strong differences are applicable among countries and regions. Specifically in the south-eastern part of Europe – namely in Bulgaria, Hungary and Romania – actual developments have been lacking far behind earlier expectations. This was mainly driven by hurdles and changes in legislation, or a lack of political emphasis. Moreover, up to our knowledge, there is from a scientific viewpoint still a lack of detailed analysis concerning the potential that is applicable for wind power development in that part of Europe.

1.2 Goal of this study

This study aims to shed light on the applicable potentials for wind power development in Bulgaria, Hungary and Romania, indicating and informing decision makers and stakeholders how wind power may contribute to meet the future demand for electricity in a carbon-neutral manner.

For that purpose, a thorough technical analysis of the future potential for wind power at the countryside (onshore) as well as, where available, in marine areas (offshore) is conducted for the whole study region. More precisely, a detailed GIS-based analysis of the potential for wind power development is undertaken, building on a comprehensive meteorological dataset (i.e., time-series of wind speeds for past weather years) at a high geographical resolution and incorporating spatial constraints related to competing land use (i.e., nature protection, urban, agriculture, forestry, military

use or other purposes that limit the suitability for wind power and related grid development). Additionally, sensitivity analyses are done for key input parameter (incl. distance rules, turbine design and preferences in land use) based on a pre-identification of the relevance of above listed factors to shape the analysis to the country specific needs. A mapping exercise is then conducted to indicate how identified promising areas for wind power development match with the transmission grid infrastructure. Complementary to the above, a model-based assessment of the impacts of an enhanced wind uptake in future years on the underlying electricity market is conducted as final analytical step.

The outcome of this assessment are detailed maps showing available areas for wind power development as well as corresponding site qualities, and a comprehensive dataset that lists the identified wind power potential at regional level within a country (i.e., by NUTS-3 region). Brief country reports inform on the results derived and the underlying approach taken, suitable for the targeted audience. A more comprehensive background report will inform interested actors on further technical details concerning methodology and results.

This country report is dedicated to informing on **the approach and the results derived for Romania**, informing on the **identified wind power potentials** and the **electricity market impacts of an enhanced wind uptake** in future years.

1.3 Structure of this report

This report is structured as follows: After the introduction provided in Chapter 1, subsequently in Chapter 2 the method of approach is described. Chapter 3 is then dedicated to present the outcomes of the GIS-based analysis of wind power potentials in Romania whereas Chapter 4 shows the market impacts of an enhanced wind uptake in future years. The report closes with a list of conclusions and recommendations on the way forward.

2 METHOD OF APPROACH

The work required for meeting the study objectives can be clustered into three tasks that generally follow a consecutive order, with some interactions in between, including:

- Task 1: GIS-based analysis of the wind power potentials
- Task 2: Complementary assessment of electricity market impacts of an enhanced wind deployment
- Task 3: Stakeholder consultation and dissemination activities

Below we describe the approach and key assumptions for task 1 and 2 in further detail.

2.1 Task 1: GIS-based analysis of the wind power potential

2.1.1 Brief overview on the approach taken

As central element of this study, a thorough technical analysis of the future potential for wind power at the countryside (onshore) as well as, where available, in marine areas (offshore) is undertaken for the whole study region.

Overview on the approach taken: (exemplified for wind onshore potentials)

- **Matching of wind speed data with wind turbine power curve**
→ **Load factors** (full load hours) **by pixel**
- **Consideration of distance rules to the built environment**, e.g., 1.2 km to housing, etc.
- **Exclusion** (or illustrative inclusion) of **nature protection areas and other land use categories** (e.g., built environment, inland waters, etc.) not suitable for wind power development

⇒ **Technical potentials w/o land use constraints** Expressed as area potentials (km²) as well as in capacity (MW) and energy terms (GWh)

- **Application of further land use restrictions:**

⇒ **Technical potentials with land use constraints**

Least-cost allocation Preference to best sites within a region

Balanced allocation Balanced allocation of wind sites (i.e., using average suitability factors)

Figure 1: Overview on the approach taken for the assessment of wind potentials in the study region (exemplified for onshore wind)

As illustrated by Figure 1, we conduct a GIS-based analysis of the potential for wind power development that includes the following steps:

- A comprehensive meteorological dataset on time-series of wind speeds is processed under a detailed geographical resolution for past weather years, serving as a basis for identifying unconstrained resource potentials across the whole study region, including adjacent marine areas. The underlying weather reanalysis open-source dataset is COSMO-REA6. It provides pre-calculated hourly wind speeds at 100 m and 150 m height and at

a geographical resolution of 6 km times 6 km. For our analysis, wind speed data for the years 1995 to 2018 is taken into consideration.

- As the next step within the GIS-based assessment, spatial constraints are incorporated that stem from competing land use, such as nature protection (e.g., by excluding Natura 2000 protected areas), urban, agriculture, military use or other purposes that limit the suitability for wind power production and related grid deployment. Offshore wind is according to past experiences less relevant for the Black Sea region but recently gaining key policy attention at the European as well as the national level. Specifically, for offshore wind, competing uses of the sea (e.g., main shipping routes, nature protection areas and specifically tourism) are taken into consideration (i.e., by excluding related areas from the applicable resource base as a simplification).
- Sensitivity analyses are performed for key parameter affecting the applicable wind power potential, including – in the case of Romania – the impact of excluding vs including nature protection areas and, specifically for offshore wind power, details on the applied wind turbine design (i.e., rotor area in relation to generator size). For Romania these aspects appear of relevance as identified in stakeholder consultations undertaken in prior. Apart from Romanian specifics we also illustrate the impact of further land use restrictions on those areas classified as being feasible for wind power development. That aims to increase social acceptance of wind power and may allow for a more rapid uptake in future years, once other barriers are removed. In this context, two different variants are assessed:
 - Balanced allocation: Balanced allocation of wind sites by using average suitability factors as listed in Table 1 below.
 - Least-cost allocation: Preference to best sites within the country, implying higher suitability factors as shown in Table 1 and, in turn, lower ones for less windy areas within a region.

Table 1: Average suitability factors applied for the identification of wind power potentials with (consideration of further) land use restrictions

Land use category	Average suitability factor
Built environment, Inland waters, wetlands	0%
Agricultural areas	40%
Forestry areas	10%

- A mapping exercise is finally conducted to indicate how identified promising areas for wind power development match with the transmission grid infrastructure.

The outcome of this assessment are detailed maps showing available areas for wind power development as well as corresponding site qualities (in terms of capacity factors / full load hours) in dependence of sensitivity parameter, and a comprehensive dataset that lists the identified wind power potential at regional level within a country (i.e., by NUTS-3 region), incl. information on wind site qualities. Complementary to the country reports prepared, a more comprehensive background report will inform interested actors on further technical details concerning methodology and results, cf. Resch et al. (2023).

2.1.2 Background information and technical details

For the interested reader we subsequently provide further details on the approach taken for estimating and reporting on wind potentials.

Software tools: For the GIS analysis a set of software tools are used, including CDO (Climate Data Observer, cf. Schulzweida et al. (2019)), Python and GDAL (Geospatial Data Abstraction Library, cf. Rouault E., 2022). Source code and input data are available at <https://github.com/ait-energy/wind.power.potential-BG-HU-RO> so that derived results are reproduceable or can be adapted in the case of alternative input data etc. Complementary to the above, QGIS, an open-source software tool, is used for map generation.

Details on approach and assumptions:

- As first step, to derive estimates on the electricity generation potential, **wind speed data** taken from COSMO-REA6, representing a global reanalysis of meteorological data combined with a large set of observations (cf. Bollmeyer et al., 2014) is **matched with a wind turbine power curve**. The result is an hourly time-series for all COSMO-REA6 pixels with theoretical load factors. The average load factor over all hours, ranging from 1995 to 2018, is calculated and serves as base for further calculations. The load factor is thereby expressed as full load hours, describing the virtual hours within a calendar year that a power plant operates at its rated power.¹ The following turbine characteristics are thereby applied:
 - As default our onshore wind turbine is the Nordex N163, characterised by a hub height of 150 m and a rotor diameter of 163 m. That turbine is equipped with a 4.95 MW electric generator.
 - For offshore the standard turbine is the VESTAS V164/8000, at hub height of 150m and a rotor diameter of 164 m, equipped with an 8 MW electric generator.
- Next, processed wind data is **matched with land use information** taken from the CORINE land use database (as of 2021). Land use data comes at a detailed geographical resolution (100 m x 100 m), requiring a retransformation of the wind data.
- Retransformed data is subsequently masked, and an **efficiency factor of 0.85** is applied to account for losses due to wind shading effects within a wind farm as well as maintenance, etc.
- **Exclusion of certain areas:** The process of masking comprises also the exclusion of areas not suitable for wind power development due to different constraints and aspects:
 - Techno-economic constraints: We exclude areas above an altitude of 2000 m and above a slope of 20° to account for possible technical challenges and/or high cost related to grid connection.
 - Nature protection: As default, we also exclude nature protection areas from our identification of wind development potentials. Information on protected areas is thereby taken from the UN World Database of Protected Areas (WDPA), cf. IUCN and UNEP-

¹ Full load hours are derived by multiplying the load factor with 8760, representing on average the number of hours within a calendar year. In reality, a wind power plant is generally during more hours in operation than indicated by the full load hours since during many hours the plant operates at partial load.

WCMC (2020).² In our GIS modelling, all nature protection areas are buffered with 1200 m (to reflect a sufficient distance of possible wind power developments) and then excluded.

Upon request by some stakeholder, for sensitivity purposes we also illustrate the impact of including nature protection areas in our classification of go-to areas for on-shore wind power development. That dataset is clearly marked as “Including Nature Protection Areas”. Please note further that for onshore wind we generally exclude also inland waters and wetlands to account for nature protection as well as trade-offs with other purposes like shipping. For those areas a buffering with 600 m is applied, representing a further distance restriction for possible wind power development.

- Social acceptance and avoidance of use conflicts: Built-up areas (incl. artificial surfaces like urban fabrics, industrial or commercial units, port areas, airports, construction sites, green urban areas, sport and leisure facilities) and infrastructure areas (incl. road and rail networks and associated land, mineral extraction sites, dump sites) are generally excluded. For the built-up areas a buffering of 1200 m is applied, respecting that wind power development should not harm the local community via noise or shading, etc.
- Economic constraints: We exclude areas of low wind speeds to account for the economic viability of wind power development. That implies to exclude areas below 1,700 effective full load hours (i.e., considering the efficiency factor of 0.85 as discussed above) in the case of onshore wind, and below 2,000 effective full load hours for offshore wind.

Please note that for the calculation of offshore wind potentials, the same principles apply concerning nature protection. There are no land cover restrictions considered but shipping routes in the Black Sea are excluded instead. Starting with raster data from global shipping traffic densities³, the mostly used shipping routes are manually drawn as lines with 10 km width and then excluded.

- **Classification by area:** For the further processing in database format, the values of the usable (i.e., not excluded) pixels are aggregated by administrative boundaries. For on-shore wind this implied a breakdown by NUTS region and a distinction between wind power site qualities (i.e., 12 categories of different wind site qualities, represented by ranges of full load hours, predefined for the whole study region) and by land use type (i.e., into 14 land use categories according to the level two classification of the CORINE

² According to the provided information on the respective website (<https://www.protectedplanet.net/en/thematic-areas/wdpa?tab=WDPA>), the WDPA is the most comprehensive global database of marine and terrestrial protected areas. It is a joint project between UN Environment Programme and the International Union for Conservation of Nature (IUCN) and is managed by UN Environment Programme World Conservation Monitoring Centre (UNEP-WCMC), in collaboration with governments, non-governmental organisations, academia and industry.

³ Cf. <https://datacatalog.worldbank.org/search/dataset/0037580>

land use database). For offshore wind the breakdown into 12 categories respects differences in water depth and distance to the shore, with impact on corresponding cost of electricity generation and wind farm design.

2.2 Task 2: Complementary assessment of electricity market impacts of an enhanced wind deployment

Based on the wind potential assessment of the previous task, REKK, using the EPMM model, estimates the economic impacts of these developments under varying levels of wind capacities. This is a crucial aspect of this development, as wind generation was lagging in all analysed countries – i.e., mainly in Hungary and Bulgaria, but also in Romania wind development has stopped after 2014.

The modelling focusses on the following economic aspects:

- Impact on wind market value: in contrast to the PV developments, wind capacity expansion generally maintains the market values of wind generation, due to its less cyclical nature, which in a long term could give high advantages to wind-based generation.
- The modelling will also reveal the impacts on the reserve market developments in these countries. Higher wind development can increase the demand for reserve capacity services, but they could also contribute to downward regulation, so the modelling can reveal how can wind contribute to this market segment.
- Impact on baseload prices, on import/export positions of the countries as well as on carbon emissions will also be reported and analysed.

2.2.1 Modelling approach

The European Power Market Model (EPMM) is a unit commitment and economic dispatch model. Electricity consumption is satisfied simultaneously in all modelled countries at a minimum system cost, spinning reserve requirements, capacity constraints of the available power plants and cross-border transmission capacities. The cost elements considered in the model include start-up and minimum down-time of the power plants, production (mainly fuel and CO₂ costs) and curtailment. The model simultaneously optimises all 168 hours of a modelled week and determines the hours of operation and reserve levels. The model is executed for 12 representative weeks of the given year (each month is represented by one week). The EPMM endogenously models 41 electricity markets in 38 countries of the ENTSO-E network.

2.2.2 Scenario set-up

Three scenarios are modelled, which differ by the assumed uptake of wind in all analysed countries:

- low wind penetration
- moderate wind penetration
- high wind penetration

In all other aspects there are no differences between the scenarios. Below Figure 2 illustrates the assumed country-specific wind capacities for the three scenarios for the assessed years (2030, 2040 and 2050). Assumptions taken in this respect for Romania are as follows:

- The “low wind penetration” scenario implies an increase of wind deployment from at present (2021) 3.0 GW to 4.0 GW by 2030, increasing steadily further up to 8.0 GW by 2050.

- In contrast to the above, in the “high wind penetration” scenario a significantly stronger uptake of wind power is presumed, reaching 8.1 GW already by 2030. Wind is then expected to increase further up to 22.2 GW by 2050.
- The scenario of “moderate wind penetration” implies a moderate growth of wind power in future years, with assumed installed capacities lying in between the low and the high. For Romania this results in an increase of wind deployment from at present (2021) 3.0 GW to 5.8 GW by 2030, increasing further up to 14.1 GW by 2050.




Figure 2: Wind installed capacities in the three analysed scenarios in the modelled years, MW

The outcomes of this complementary analysis are presented in Chapter 4 of this report, as a topical extension to inform on the outcomes and electricity market impacts of an enhanced wind uptake in future years. Please note that further details on the approach taken, specifically on assumptions can be found in the complementary technical background report, cf. Resch et al. (2023).

3 RESULTS OF THE GIS-BASED ANALYSIS OF WIND POTENTIALS IN ROMANIA

This chapter is dedicated to informing on the results of the GIS-based analysis of wind power potentials in Romania, comprising both wind development at the countryside (onshore) and in marine areas (offshore). Building on the approach described in the previous chapter, specifically section 2.1, we discuss subsequently the results related to onshore wind. Next to that results on offshore wind are presented. Finally, the study findings are put into a broader energy system context, illustrating the role wind may be able take in future electricity supply within Romania.

3.1 Onshore wind potentials

Looking at the topographical context as described in Wikipedia⁴, Romania's natural landscape is almost evenly divided among mountains (31 percent), hills (33 percent), and plains (36 percent). In terms of size the country is the twelfth largest within Europe, covering an area of 238 thousand square km. The backbone of Romania is formed by the Carpathian Mountains, which reach elevations of more than 2,400 meters. The Carpathians extend over 1,000 km through the centre of the country, covering an area of 70,000 square km. These mountains are deeply fragmented by longitudinal and transverse valleys and crossed by several major rivers. Romania's lowest land is found on the northern edge of the Dobruja region in the Danube Delta. The delta is a triangular swampy area of marshes, floating reed islands, and sandbanks, where the Danube ends its trek of almost 3,000 km and divides into three frayed branches before emptying into the Black Sea.

3.1.1 Technical potentials at the national level

According to the GIS-based analysis conducted in this study, slightly less than a fourth of the country (i.e., 22.8% of the total area) appears suitable for onshore wind power development, considering constraints ranging from a techno-economic, a societal and a nature conservation perspective (i.e., by excluding nature protection areas) as described in section 2.1.2. If all identified sites being classified as feasible would actually be used for wind power development, an enormous technical potential for wind power occurs: Thus, as listed in Table 2, the country area suitable for wind power development comprises 54 thousand square km, corresponding to a capacity potential of 499 GW. That would allow to generate electricity in size of 1,047 TWh per year, reflecting average meteorological conditions. To put that into a perspective, Romania's gross electricity consumption amounted to 61 TWh in 2021. From a technical potential, Romania could generate more than seventeen times more electricity from onshore wind power than currently consumed. Apart from other barriers, a limiting factor to that is however the power grid infrastructure which is far from being ready to absorb these enormous amounts of electricity.

If one classifies nature protection areas as being suitable for wind power development, the technical potential increases further on, cf. Table 2: The area potential would then grow up to 85 thousand

⁴ Cf. https://en.wikipedia.org/wiki/Romania#Geography_and_climate and https://en.wikipedia.org/wiki/Topography_of_Romania.

square km, corresponding to a capacity potential of 784 GW and a yearly electricity generation of 1,680 TWh.

Table 2: Technical potentials for onshore wind power development in Romania, neglecting land use constraints (at feasible areas), expressed in area, capacity and energy terms. Source: own analysis.

Scenario	Area potential total usable area [ha]	Technical potential w/o land use constraints		
		Capacity potential [MW]	Energy potential [GWh]	Average full load hours [h/a]
		Excl. Nature Protection Areas	5,421,656	498,812
Incl. Nature Protection Areas	8,524,566	784,291	1,679,550	2,141

If we limit the wind power development by applying further land use restrictions on those areas classified as being feasible for wind power development, we still end up with significant potentials for onshore wind development in Romania as shown in Table 3. Doing so may maintain social acceptance of wind power in general, and it may also allow for a more rapid uptake in future years – once other barriers are removed. As discussed in section 2.1.1, two different variants are assessed:

- **Balanced allocation:** Balanced allocation of wind sites by using average suitability factors for agricultural (40%) and forestry areas (10%).
- **Least-cost allocation:** Preference to best sites within Romania, implying higher suitability factors as shown in Table 1 and, in turn, lower ones for less windy areas within the country.

According to Table 3, the identified technical potential for onshore wind in Romania, with consideration of (further) land use restrictions, amounts to ca. 166.5 GW – about one third of the unconstrained technical potential. The corresponding yearly electricity generation varies among both allocation options: following a balanced approach implies a yearly electricity generation in size of 355 TWh whereas the adoption of a least-cost allocation within each region increases the generation potential up to 364 TWh.

Table 3: Technical potentials for onshore wind power development in Romania, with (further) land use constraints (at feasible areas), expressed in capacity and energy terms for assessed allocation options (least-cost vs balanced). Source: own analysis.

Scenario	Technical potential with land use constraints (Least-Cost)			Technical potential with land use constraints (Balanced)		
	Capacity potential [MW]	Energy potential [GWh]	Average full load hours [h/a]	Capacity potential [MW]	Energy potential [GWh]	Average full load hours [h/a]
	Excl. Nature Protection Areas	166,463	364,098	2,187	166,764	354,734
Incl. Nature Protection Areas	240,019	538,079	2,242	234,196	506,369	2,162

A graphical illustration of the identified onshore wind development potentials in Romania is provided by Figure 3. From this graph the large differences between the technical potentials where all areas classified as suitable for wind power development (i.e., without land use constraints) would be used versus the smaller technical potentials derived by consideration of further land use restrictions. Thus,

if only 40% of agricultural areas and 10% of forestry areas (not classified as nature protection areas) would be used, the technical potentials are reduced to about one third of the unconstrained one.




Figure 3: Technical potentials for onshore wind in Romania, w/o and with (further) land use constraints (at feasible areas), expressed in capacity (left) and energy terms (right) for assessed allocation options (least-cost vs balanced). Source: own analysis.

3.1.2 Technical potentials at the regional level


In accordance with the above, we now undertake a deep dive into the regions within Romania, presenting the outcomes of our GIS-based analysis of the onshore wind potentials at a regional level. In practical terms, we thereby follow the standardised NUTS-3 classification for the European Union and consequently undertake a breakdown of the results for the whole of Romania by region. In the case of Romania this implies to distinguish between 42 regions as applicable in the subsequent graphs and tables.

In this context, Figure 4 provides a graphical illustration of areas suitable for wind power development within Romania. More precisely, this figure shows wind maps for Romania, indicating for wind power development areas via a colour code that informs on corresponding wind site qualities, expressed via on average achievable full load hours, using the underlying state-of-the-art onshore wind power turbine (cf. section 2.1.2). This figure contains two graphs, the upper one shows the wind map excluding nature protection areas whereas to one at the bottom informs also on wind site qualities for those parts within nature protection areas. As applicable from these depictions, some of the best wind sites can be found in the eastern part of Romania, specifically where the Danube ends in the Black sea. Large parts of the region Tulcea but also of Constanța are classified as nature protection areas which consequently reduces the wind power development potential there, supposing that those areas are not classified as suitable for wind power development. Despite of these constraints, the technical potential for wind power development is significant: these two regions alone have space for 33.8 GW of wind power, corresponding to a yearly electricity generation of 88.4 TWh – by far more than Romania consumes at present. There are however more regions within Romania that do offer promising wind conditions. If we expand the list to the five best regions within the country, in addition to Tulcea and Constanța also Brăila, Galați and Ialomița have to be named. The technical potential for wind power sums then up to 98.9 GW or 249.2 TWh, respectively. Achievable full load

hours of wind sites within these regions are on average (well) above 2,350 hours per year – this characterises also from a European perspective comparatively good wind development areas.

hirner@bitfire.at 2023-06-27

Calculated wind potential map: Romania



hirner@bitfire.at 2023-06-27

Calculated wind potential map: Romania




Figure 4: Wind maps for Romania, indicating site qualities (expressed in full load hours) and by excluding (top) vs including (bottom) nature protection areas. Source: own analysis.

The technical details on wind potentials and average site qualities per region as discussed above are listed in Table 4 below. This table offers a breakdown of the technical potentials for wind power development in Romania by NUTS-3 region, without consideration of further land use constraints for available areas and by excluding (left) or including (right) nature protection areas.

Table 4: Breakdown of the technical potentials for wind power development in Romania by NUTS-3 region, without consideration of further land use constraints for available areas and by excluding (left) or including (right) nature protection areas. Source: own analysis.

Region	Excl. Nature Protection Areas				Incl. Nature Protection Areas			
	Area potential total usable area [ha]	Technical potential w/o land use constraints			Area potential total usable area [ha]	Technical potential w/o land use constraints		
		Capacity potential [MW]	Energy potential [GWh]	Average full load hours [h/a]		Capacity potential [MW]	Energy potential [GWh]	Average full load hours [h/a]
Braşov	33,558	3,087	5,722	1,853	63,521	5,844	11,097	1,899
Timiș	303,916	27,961	57,171	2,045	394,463	36,292	74,960	2,065
Teleorman	328,030	30,180	57,014	1,889	374,592	34,464	64,755	1,879
Covasna	37,215	3,424	6,825	1,993	60,925	5,605	10,975	1,958
Vaslui	195,981	18,031	39,968	2,217	256,567	23,605	52,660	2,231
Brăila	245,113	22,551	57,128	2,533	344,818	31,725	80,386	2,534
Prahova	57,449	5,286	10,491	1,985	80,258	7,384	14,902	2,018
București	10	1	2	1,750	10	1	2	1,750
Arad	195,416	17,979	35,329	1,965	291,782	26,845	52,417	1,953
Caraș-Severin	171,006	15,733	31,854	2,025	374,827	34,485	71,351	2,069
Hunedoara	15,388	1,416	2,596	1,833	49,930	4,594	8,538	1,859
Sălaj	72,099	6,633	11,763	1,773	86,274	7,938	14,372	1,811
Gorj	645	59	105	1,772	58,697	5,400	11,080	2,052
Harghita	36,474	3,356	5,922	1,765	100,176	9,217	16,376	1,777
Neamț	112,065	10,310	19,529	1,894	158,145	14,550	27,556	1,894
Maramureș	18,169	1,672	3,149	1,884	62,049	5,709	10,704	1,875
Satu Mare	146,267	13,457	27,666	2,056	179,994	16,560	34,205	2,066
Suceava	199,457	18,351	34,306	1,869	270,597	24,896	47,017	1,889
Ilfov	31,354	2,885	5,050	1,751	35,299	3,248	5,671	1,746
Dolj	305,296	28,088	55,327	1,970	433,222	39,858	77,070	1,934
Alba	11,173	1,028	1,867	1,816	33,130	3,048	5,576	1,829
Buzău	256,048	23,557	51,709	2,195	322,801	29,699	65,396	2,202
Constanța	287,225	26,426	69,310	2,623	487,218	44,826	116,338	2,595
Cluj	16,770	1,543	2,916	1,890	66,038	6,076	11,573	1,905
Galați	228,953	21,065	52,911	2,512	286,535	26,362	65,314	2,478
Tulcea	80,143	7,373	19,096	2,590	639,393	58,826	168,664	2,867
Iași	149,156	13,723	27,190	1,981	235,163	21,636	43,212	1,997
Bihor	146,558	13,484	27,054	2,006	295,876	27,222	54,817	2,014
Vrancea	195,122	17,952	37,683	2,099	301,002	27,693	57,175	2,065
Giurgiu	156,883	14,434	27,002	1,871	212,822	19,580	36,278	1,853
Argeș	80,650	7,420	13,268	1,788	103,249	9,499	17,254	1,816
Bacău	188,814	17,372	33,782	1,945	235,834	21,698	42,069	1,939
Ialomița	233,262	21,461	50,785	2,366	314,273	28,914	67,866	2,347
Mureș	32	3	5	1,676	30,262	2,784	5,031	1,807
Sibiu	29,591	2,722	4,838	1,777	99,739	9,176	16,863	1,838
Olt	230,813	21,236	40,648	1,914	279,655	25,729	48,697	1,893
Mehedinți	90,956	8,368	16,585	1,982	193,719	17,823	34,693	1,947
Vâlcea	10,627	978	1,784	1,825	47,805	4,398	8,657	1,968
Botoșani	199,402	18,346	38,384	2,092	252,065	23,191	48,525	2,092
Bistrița-Năsăud	106	10	16	1,624	10,904	1,003	1,728	1,722
Călărași	305,993	28,152	60,761	2,158	373,176	34,334	73,096	2,129
Dâmbovița	18,471	1,699	2,911	1,713	27,761	2,554	4,634	1,814
Romania	5,421,656	498,812	1,047,422	2,100	8,524,566	784,291	1,679,550	2,141

As state above, if we limit the wind power development by applying further land use restrictions on those areas classified as being feasible for wind power development, we still end up with significant

potentials for onshore wind development in Romania. This is shown in Table 3 at the country level and in Table 5 at a regional level, following a least-cost allocation by giving preference to best sites within Romania. A graphical illustration of the numbers listed in Table 5 is given by Figure 5, indicating the capacity potentials (top) and the corresponding average full load hours per region, again by including or excluding nature protection areas.

Table 5: Breakdown of the technical potentials for wind power development in Romania by NUTS-3 region, with consideration of further land use constraints for available areas (via a least-cost allocation) and by excluding (left) or including (right) nature protection areas. Source: own analysis.

Region	Excl. Nature Protection Areas			Incl. Nature Protection Areas		
	Technical potential with land use constraints (Least-Cost)			Technical potential with land use constraints (Least-Cost)		
	Capacity potential [MW]	Energy potential [GWh]	Average full load hours [h/a]	Capacity potential [MW]	Energy potential [GWh]	Average full load hours [h/a]
Braşov	367	690	1,883	701	1,358	1,939
Timiș	10,112	21,023	2,079	13,242	27,792	2,099
Teleorman	10,125	19,166	1,893	11,215	21,157	1,886
Covasna	363	743	2,047	581	1,167	2,010
Vaslui	6,612	14,803	2,239	8,541	19,196	2,247
Brăila	11,142	28,384	2,547	14,791	37,724	2,550
Prahova	709	1,403	1,979	1,038	2,087	2,011
București	0	0	1,750	0	0	1,750
Arad	5,709	11,482	2,011	8,404	16,733	1,991
Caraș-Severin	3,075	6,247	2,032	5,713	11,904	2,084
Hunedoara	149	274	1,846	449	851	1,894
Sălaj	1,491	2,649	1,776	1,707	3,086	1,808
Gorj	5	10	1,810	612	1,305	2,132
Harghita	298	526	1,767	838	1,496	1,785
Neamț	2,112	4,164	1,972	2,793	5,507	1,972
Maramureș	229	434	1,895	626	1,191	1,904
Satu Mare	4,249	8,817	2,075	5,296	11,052	2,087
Suceava	3,158	6,170	1,954	4,184	8,236	1,969
Ilfov	784	1,374	1,753	835	1,461	1,751
Dolj	9,559	18,981	1,986	12,526	24,532	1,959
Alba	132	239	1,816	357	653	1,829
Buzău	7,882	17,863	2,266	9,494	21,579	2,273
Constanța	13,698	36,309	2,651	21,048	55,253	2,625
Cluj	211	397	1,880	701	1,350	1,926
Galați	9,840	24,878	2,528	11,864	29,631	2,498
Tulcea	3,703	9,792	2,644	22,870	66,221	2,896
Iași	4,210	8,342	1,982	6,093	12,125	1,990
Bihor	3,950	8,034	2,034	7,214	14,817	2,054
Vrancea	4,915	10,769	2,191	6,376	13,785	2,162
Giurgiu	4,429	8,334	1,882	5,645	10,546	1,868
Argeș	2,135	3,837	1,797	2,387	4,318	1,809
Bacău	3,153	6,353	2,015	3,791	7,576	1,998
Ialomița	9,685	23,222	2,398	12,347	29,440	2,384
Mureș	0	0	1,676	228	415	1,822
Sibiu	627	1,105	1,763	1,497	2,710	1,810
Olt	6,952	13,391	1,926	8,006	15,298	1,911
Mehedinți	2,604	5,164	1,983	4,383	8,598	1,962
Vâlcea	96	177	1,837	489	992	2,027
Botoșani	6,478	13,590	2,098	7,714	16,191	2,099
Bistrița-Năsăud	1	1	1,624	81	141	1,736
Călărași	11,074	24,205	2,186	12,785	27,623	2,161
Dâmbovița	442	753	1,705	556	979	1,759
Romania	166,463	364,098	2,187	240,019	538,079	2,242

Complementary to the above, Table 6 provides further insights on the distribution of the region-specific technical potentials among wind site classes, expressed by the respective range of full load hours. This is done under consideration of land use constraints, assuming again a least-cost allocation as well as by excluding nature protection areas.

Table 6: Breakdown by wind site class (i.e., full load hour ranges) of the region-specific technical potentials for wind power development in Romania, expressed in capacity terms (MW), with consideration of land use constraints (least-cost allocation) and with exclusion of nature protection areas. Source: own analysis.

Region	Technical potential with land use constraints (least-cost) in capacity terms (in MW) in total (left column) and by wind site class, expressed by the range of respective full load hours (all other columns)								
	all wind classes [MW]	flh 1600-1850 [MW]	flh 1850-2100 [MW]	flh 2100-2300 [MW]	flh 2300-2500 [MW]	flh 2500-2700 [MW]	flh 2700-2900 [MW]	flh 2900-3100 [MW]	flh 3100-3300 [MW]
Braşov	367	218	54	65	22	8			
Timiș	10112	1686	2916	4023	1487				
Teleorman	10125	1791	8334						
Covasna	363	57	205	51	12	38			
Vaslui	6612	84	1140	3122	1661	548	57		
Brăila	11142		51	1032	2319	6465	1275		
Prahova	709	260	190	128	132				
București	0	0							
Arad	5709	1325	1885	2499					
Caras-Severin	3075	1263	699	453	210	398	1	51	
Hunedoara	149	91	34	24					
Sălaj	1491	1104	369	18					
Gorj	5	4		1					
Harghita	298	233	65						
Neamț	2112	548	1077	455	32				
Maramureș	229	81	104	44					
Satu Mare	4249	159	1926	2001	163				
Suceava	3158	841	1603	656	58				
Ilfov	784	717	67						
Dolj	9559	1590	5418	2551					
Alba	132	80	9	39	3				
Buzău	7882	822	904	2120	2659	1365	13		
Constanța	13698		168	383	2818	4213	4318	1456	342
Cluj	211	117	63	2	30				
Galați	9840		52	1084	3339	2953	2306	106	
Tulcea	3703	14	197	293	743	602	966	692	196
Iași	4210	805	2727	460	207	11			
Bihor	3950	516	1701	1690	43				
Vrancea	4915	489	902	1814	1190	469	51		
Giurgiu	4429	1757	2672						
Argeș	2135	1532	604						
Bacău	3153	790	929	1362	72				
Ialomița	9685	227	976	1213	3543	3726			
Mureș	0	0							
Sibiu	627	495	131						
Olt	6952	1779	4687	485					
Mehedinți	2604	570	1494	446	19	48		26	
Vâlcea	96	56	32	5		2			
Botoșani	6478	51	3659	2476	292				
Bistrița-Năsăud	1	1							
Călărași	11074	326	3745	3246	3249	508			
Dâmbovița	442	436		5					
Romania	166,463	22,917	51,786	34,247	24,301	21,355	8,989	2,330	538




Figure 5: Breakdown of the technical potentials for wind power development in Romania by NUTS-3 region, with consideration of further land use constraints for available areas (via a least-cost allocation) and by excluding or including nature protection areas. Expressed are capacity potentials (top) and average site qualities (full load hours) per region. Source: own analysis

A closer look at the regional breakdown of technical capacity potentials and corresponding average full load hours shown in Figure 5 reveals that five regions within Romania can be classified as (very) good concerning wind site qualities. As discussed above, that top-five list includes the regions Tulcea, Constanța, Brăila, Galați and Ialomița, and achievable full load hours of wind sites within these regions are on average (well) above 2,350 hours per year. The overall technical potential for wind power of all five regions together sums up to 98.9 GW or 249.2 TWh, respectively, cf. Table 4. If we now apply further land use constraints and thereby assume a least-cost allocation for the whole of Romania, then this would limit the technical potential to the half, i.e., 48.1 GW or 122.6 TWh, respectively. However, even the smaller number in terms of generation potential is twice as high as the electricity consumption of the whole of Romania at present. Focussing on these areas may allow to better tackle one key barrier to an enhanced wind power uptake: the necessary grid expansion. At present many Romanian stakeholders classify this as the central hurdle for a rapid uptake of this promising carbon-free energy carrier.

3.1.3 Mapping with the grid infrastructure

A mapping exercise is finally conducted to indicate how identified promising areas for onshore wind power development match with the transmission grid infrastructure. We consequently add to the dataset an indicator that shows the average distance to the next grid node for feasible wind development areas, on average by region as well as on average for each available wind site class within a region, cf. Table 7. Thus, on average wind farms in Romania are 30 km distant to the next grid node, with variations among individual sites but with hardly any differences by wind site class.

Table 7: Average distance to the next transmission grid node of region-specific feasible wind development areas in Romania, considering the technical potentials with land use constraints (least-cost allocation) and with exclusion of nature protection areas, expressed on average by region (left column) as well as by wind site class (all other columns). Source: own analysis.

Average distance of individual pixels to the next grid node (in km) on average (left column) and by wind site class, expressed by the range of respective full load hours (all other columns)

Region	all wind classes [km]	flh 1600-1850 [km]	flh 1850-2100 [km]	flh 2100-2300 [km]	flh 2300-2500 [km]	flh 2500-2700 [km]	flh 2700-2900 [km]	flh 2900-3100 [km]	flh 3100-3300 [km]
Braşov	24	25	25	18	29	34			
Timiș	31	29	22	31	60				
Teleorman	35	31	36						
Covasna	49	48	48	46	56	57			
Vaslui	30	24	29	32	29	23	56		
Brăila	25		26	19	18	28	35		
Prahova	31	34	32	28	30				
București	6	6							
Arad	31	28	25	38					
Caras-Severin	35	36	38	33	33	31	29	31	
Hunedoara	19	21	14	17					
Sălaj	19	18	22	33					
Gorj	12	11		14					
Harghita	36	36	36						
Neamț	22	25	20	16	15				
Maramureș	39	45	38	32					
Satu Mare	23	17	18	29	37				
Suceava	47	59	37	33	38				
Ilfov	15	15	17						
Dolj	30	26	30	35					
Alba	22	21	13	26	22				
Buzău	34	28	32	33	37	40	57		
Constanța	20		21	20	14	17	26	31	5
Cluj	19	21	17	20	19				
Galați	37		56	37	34	37	43	61	
Tulcea	13	29	23	9	11	16	10	16	13
Iași	30	23	32	32	34	33			
Bihor	30	31	27	32	40				
Vrancea	27	29	22	25	29	39	54		
Giurgiu	20	24	17						
Argeș	26	24	34						
Bacău	27	26	24	29	36				
Ialomița	31	30	37	36	36	23			
Mureș	53	53							
Sibiu	17	18	13						
Olt	30	26	31	50					
Mehedinți	24	26	24	20	28	27		28	
Vâlcea	22	21	23	28		29			
Botoșani	55	39	53	60	51				
Bistrița-Năsăud	90	90							
Călărași	27	23	30	26	23	27			
Dâmbovița	41	41		40					
Romania	30	30	28	30	32	31	39	34	9

3.2 Offshore wind potentials (from a cross-border perspective)

This section is dedicated to put, complementary to the analysis of onshore wind potentials, offshore wind power into the spotlight. Offshore wind is according to past experiences less relevant for the Black Sea region but recently gaining key policy attention at the European as well as the national level. Specifically, for offshore wind, competing uses of the sea (e.g., main shipping routes, nature protection areas) are taken into consideration within our analysis, done by excluding related areas

from the applicable resource base as a simplification. To put the identified offshore resources of Romania into perspective, we include in addition to Romania also Bulgaria in our result assessment. In this context, Figure 6 provides a graphical illustration of applicable offshore potentials. More precisely, this graph provides an offshore wind map for the Black Sea region of Bulgaria and Romania, indicating site qualities (ex-pressed in full load hours) as well as nature protection areas and main shipping routes since both are types are excluded from the identification of potentials.




Figure 6: Offshore wind map for the Black Sea region of Bulgaria and Romania, indicating site qualities (expressed in full load hours) as well as nature protection areas and main shipping routes (both being excluded from the identification of potentials). Source: own analysis.

Complementary to Figure 6 above, the results of our potential analysis are presented in table format below. Thus, Table 8 provides an overview on the technical potentials for offshore wind power development in Bulgaria and Romania, with indication of area, capacity and energy potentials as well as site qualities (full load hours), classified according to water depth and distance to the shore, using a standard offshore turbine (large generator, large rotor – at the top of Table 8) and, for sensitivity purposes to simplify the comparison with onshore sites, a typical onshore turbine (moderate generator, large rotor – at the bottom of Table 8). As applicable from these depictions, for offshore wind both Bulgaria and Romania have promising sites at hands but generally offshore comes at higher cost compared to onshore. For an offshore wind farm upfront investment cost are about 50% to 100% higher in comparison to onshore due to higher cost for the foundations and for grid connection. Thus, this needs to be compensated by better resource qualities.

Table 8: Overview on the technical potentials for offshore wind power development in Bulgaria and Romania, with indication of area, capacity and energy potentials as well as site qualities (full load hours), classified according to water depth and distance to the shore, using a standard offshore turbine (large generator, large rotor – top) and a typical onshore turbine (moderate generator, large rotor – bottom). Source: own analysis.

Wind turbine specification:

VESTAS V164/8000

Generator size	8 MW
Rotor diameter	164 m
Area for one turbine	0.54 km ²
MW per km ²	14.7 MW/km ²

GIS-based analysis of potentials for offshore wind energy

Country:		Bulgaria				Romania			
Water depth (z, in m)	distance from shore (1 km)	Area potential (km ²)	Capacity potential (MW)	Full load hours (h/a)	Energy Potential (GWh)	Area potential (km ²)	Capacity potential (MW)	Full load hours (h/a)	Energy potential (GWh)
-40 ≤ z	d < 12	464	6,818	2,222	15,150	186	2,728	2,336	6,372
	12 ≤ d < 24	600	8,819	2,195	19,357	303	4,444	2,533	11,257
	24 ≤ d	168	2,463	2,632	6,483	335	4,914	2,754	13,531
-80 ≤ z < -40	d < 12	380	5,575	2,427	13,530	17	247	3,051	754
	12 ≤ d < 24	628	9,228	2,507	23,137	452	6,636	2,796	18,555
	24 ≤ d	1,564	22,968	2,671	61,350	7,216	105,985	2,939	311,538
-120 ≤ z < -80	d < 12	0	0	0	0	0	0		0
	12 ≤ d < 24	181	2,659	2,570	6,832	0	0		0
	24 ≤ d	1,582	23,241	2,690	62,527	3,089	45,374	3,046	138,209
z < -120	d < 12	0	0	0	0	0	0		0
	12 ≤ d < 24	34	505	2,453	1,238	0	0		0
	24 ≤ d	19,121	280,857	2,882	809,502	7,104	104,341	2,959	308,784
TOTAL Area		34,709				29,587			
USABLE Area		24,722	363,133	2,806	1,019,105	18,700	274,670	2,945	809,001

Wind turbine specification:

Nordex N163-4.95

Generator size	4.95 MW
Rotor diameter	163 m
Area for one turbine	0.54 km ²
MW per km ²	9.2 MW/km ²

GIS-based analysis of potentials for offshore wind energy

Country:		Bulgaria				Romania			
Water depth (z, in m)	distance from shore (1 km)	Area potential (km ²)	Capacity potential (MW)	Full load hours (h/a)	Energy Potential (GWh)	Area potential (km ²)	Capacity potential (MW)	Full load hours (h/a)	Energy potential (GWh)
-40 ≤ z	d < 12	958	8,810	2,704	23,826	186	1,709	3,100	5,298
	12 ≤ d < 24	651	5,987	2,881	17,248	303	2,783	3,305	9,198
	24 ≤ d	168	1,543	3,389	5,228	335	3,078	3,529	10,863
-80 ≤ z < -40	d < 12	398	3,661	3,135	11,477	17	155	3,847	596
	12 ≤ d < 24	628	5,780	3,251	18,793	452	4,157	3,572	14,846
	24 ≤ d	1,564	14,386	3,431	49,357	7,216	66,385	3,718	246,836
-120 ≤ z < -80	d < 12	2	18	2,407	44	0	0		0
	12 ≤ d < 24	181	1,665	3,310	5,512	0	0		0
	24 ≤ d	1,582	14,558	3,450	50,227	3,089	28,421	3,830	108,865
z < -120	d < 12	0	2	2,362	6	0	0		0
	12 ≤ d < 24	34	316	3,183	1,006	0	0		0
	24 ≤ d	19,121	175,919	3,663	644,370	7,104	65,356	3,751	245,174
TOTAL Area		34,709				29,587			
USABLE Area		25,287	232,645	3,555	827,095	18,700	172,044	3,730	641,676

As applicable from Table 8 above, the overall technical potential for offshore wind in Romania is significant – i.e., 274.7 GW in capacity terms and 809.0 TWh in energy terms, respectively, when considering the standard offshore turbine for that purpose. Large parts of the most promising potentials are far-distant from the shore at sites characterised by moderate water depth or at sites with high water depth whereby the latter would recommend using a floating turbine design.

The outcomes of our offshore wind potential assessment are comparable but larger in magnitude compared previous assessments conducted in this topical context, cf. Energy Policy Group (2020) which has identified a technical potential for offshore wind in Romania in size of 94 GW. Differences in the outcomes are thereby a consequence of differing geographical boundaries and underlying assumptions concerning wind power densities.

3.3 Brief summary of results & comparison with national energy planning

This section is dedicated to summarising the results of our GIS-based analysis of wind power development potentials in Romania. To put them into perspective, we also undertake a comparison to the role of wind power in current energy planning. As starting point, Table 9 provides an overview on the identified technical potentials for wind power development in Romania, distinguishing between onshore (left) and offshore resources (right).

Table 9: Overview on identified technical potentials for wind power development in Romania, distinguishing between onshore (left) and offshore wind (right). Source: own analysis.

Summary of identified wind potentials

Technology		Onshore wind				Offshore wind			
		Technical potential with land use constraints (Least cost), incl. nature protection areas	Technical potential with land use constraints (Balanced), incl. nature protection areas	Technical potential with land use constraints (Least cost), excl. nature protection areas	Technical potential with land use constraints (Balanced), excl. nature protection areas	Near/Mid shore, low water depth	Near/Mid shore, low-medium water depth	Far shore, low-medium water depth	High water depth (floating turbines)
Type of potential									
Installed capacity	GW	240.0	234.2	166.5	166.8	7.2	6.9	156.3	104.3
Electricity generation	TWh	538.1	506.4	364.1	354.7	17.6	19.3	463.3	308.8
Full load hours	h/a	2242	2162	2187	2127	2458	2805	2965	2959

Table 10: Comparison of 2030 deployment targets for wind power and renewables in general in Romania according to current planning (left column) and under consideration of the newly established 2030 EU targets (all other columns). Sources: Republic of Romania (2019) and own analysis.

NECP targets		Current planning	New 2030 EU target (w/o top-up)	EU target (with top-up)
Planned 2030 RE share in GFEC	%	30.7	42.4	44.5
Planned 2030 RE share in gross electricity demand	%	49.4	68.2	71.6
Planned 2030 RE electricity generation	TWh	36.93	51.0	53.5
Planned 2030 wind generation	TWh	11.69	16.1	16.9
Planned 2030 wind capacity	GW	5.26	7.3	7.6

Table 10 above undertakes a comparison of 2030 deployment targets for wind power as well as renewables in general in Romania. Here we show the planned renewable and wind power uptake according to current planning as indicated in the 2019 National Energy and Climate Plan (NECP) of Romania (Republic of Romania, 2019). Recently, all EU Member States agreed on a strengthening of the renewables ambition, given the urgency to combat climate change as well as to respond on the Russian invasion of the Ukraine as well as the impact of that on Europe’s gas, and, in consequence, also on electricity supply. To acknowledge that strengthening of the renewables ambition, all EU Member States, including Romania, are currently revising their previous national energy planning. To indicate the implications on renewables in general as well as specifically on wind in energy planning, Table 10 contains deployment figures for both under the newly established EU framework on 2030 energy and climate targets. Note that these deployment figures for wind are purely indicative, derived by proportionally increasing wind in relation to the strengthened RES ambition.

Finally, Figure 7 summarises all the above. More precisely, this graph shows the status quo of wind power development (as of 2021) and compares that with the 2030 deployment targets (both according to current planning and the possible implications on that from the strengthened RES ambition) as well as with the identified wind development potentials, here exemplified for onshore wind only. Apparently, we can conclude that when considering the available wind resources in Romania that there is sufficient room for enhancing the wind uptake in future years. Given the resources at hand, wind power deserves to take a more prominent role in future energy planning in Romania. Any strengthening of the wind ambition should however go hand in hand with a strengthening of the power grid infrastructure, both at transmission and, where affected, also at the distribution grid level.




Figure 7: Wind energy at present and in future: Comparison of the status quo (2021), of 2030 deployment targets according to current planning (NECP) and under consideration of new 2030 EU targets as well as of identified technical potentials (with land use constraints). Sources: Eurostat (2023), Republic of Romania (2019) and own analysis.

3.4 Brief consideration of economics

As a teaser for the next chapter that indicates the electricity market impacts of an enhanced wind uptake in future years within Romania as well as within the neighbouring countries Bulgaria and Hungary, we conclude our resource analysis with a snapshot on the economics of wind power. At the example of onshore wind, Figure 8 depicts so-called cost-resource curves of wind onshore for all countries within our study region, including apart from Romania also Bulgaria and Hungary. These cost-resource curves show the potentials for wind onshore, using technical least-cost potentials with consideration of land use and nature protection constraints, broken down by wind site class (i.e., by full load hours) on the horizontal axes. Lines are derived by complementing the data on the resources with information on the corresponding Levelized Cost of Electricity (LCOE), using typical assumptions for cost and financial parameter as listed below. The graph confirms the previous statement that Romania offers promising wind sites at comparatively cheap cost, considering current prices on electricity wholesale markets.




Figure 8: Cost-resource curves of wind onshore in the study region (using technical least-cost potentials with consideration of land use and nature protection constraints). Source: own analysis.

Note on the assumptions for LCOE calculation: Investment cost: 1,500 EUR/kW, O&M cost: 3% p.a. (of investment cost), Interest rate: 6.5%, Depreciation time: 20 years

4 ASSESSMENT OF ELECTRICITY MARKET IMPACTS OF AN ENHANCED WIND DEPLOYMENT

This chapter is dedicated to informing on the results gained from the assessment of an enhanced wind deployment within our study region, including Bulgaria, Hungary and Romania. As outlined in section 2.2 a model-based electricity market analysis is conducted, showcasing electricity market impacts of future wind power deployment in the study region. More precisely, three scenarios are analysed, with varying assumptions on the assumed wind power uptake, ranging from a low to a high wind penetration scenario. The sections below inform on the outcomes of this analysis, with focus on Romania. Further details on the aggregated results for the whole study region are applicable in the complementary technical report (cf. Resch et al., 2023) of the underlying study.

4.1 Wholesale electricity prices

Wholesale electricity prices follow a generally decreasing trend over time in all scenarios. Figure 9 shows the modelled wholesale electricity prices in the different scenarios (left) and the price differences in the low and high wind penetration scenarios compared to the moderate scenario (right). As expected, due to the merit order effect, the higher penetration of wind capacity reduces the wholesale price in Romania in all modelled years. This price effect is significant already in 2030 (6.8 EUR/MWh between the low and high penetration scenarios), but further increases over the years, reaching 15.9 EUR/MWh in 2050. As the installed wind capacity in the three scenarios is much higher in 2050 than in 2030, the price difference is significantly higher in 2050. Wholesale electricity prices follow a generally decreasing trend over time in all scenarios.




Figure 9: Romanian baseload electricity prices in the different scenarios, €/MWh

4.2 Wind market value

As shown on the left-hand side of Figure 10, the market value of wind decreases with increasing capacity due to the merit-order effect and cannibalisation. The market value of wind is higher than the baseload price in most of the modelled years and scenarios (ranging between 101-105% of the baseload price). The only exception is the high penetration scenario in 2050, where the market value factor is 98%.




Figure 10: Wind market value in Romania in the three analysed scenarios, €/MWh (left) and % compared to base-load prices

4.3 PV market value

Like the wind market value, the PV market value also decreases over time in all scenarios, from 72-80 EUR/MWh in 2030 to 24-29 EUR/MWh in 2050. However, the PV market value is always lower than the baseload market prices: the PV market value factor is around 80% in 2030, decreasing to around 40% in 2050. The change in the PV market value due to the different wind capacity deployment is not significant: the larger wind deployment has a slightly negative impact on the PV market value.




Figure 11: PV Market value in Romania in the three analysed scenarios, €/MWh (left) and % compared to baseload prices

4.4 RES curtailment

The RES curtailment in Romania is negligible in 2030 and 2040 but increases in 2050 and varies considerably depending on the wind penetration: in the low wind penetration scenario it accounts for only 3.4% of the total PV and wind generation but reaches almost 8.6% in the high penetration scenario.




Figure 12: RES curtailment (GWh) and share of intermittent generation (%) in Romania in the three analysed scenarios

4.5 Electricity mix

Higher wind penetration in the region mainly affects Romania’s the net export ratio, with the country exporting significantly more electricity in the high wind penetration scenario than in low scenario in all modelled years.




Figure 13: Electricity generation mix and consumption in Romania in the three analysed scenarios, GWh

The introduction of wind has a significant impact on Romanian generation from 2040 onwards, with production based mainly on natural gas decreasing as more wind is present. In 2050, wind displaces a mix of gas, nuclear and PV generation.




Figure 14: Change of electricity generation from the different technologies compared to moderate wind capacities scenario, GWh

4.6 Balancing Reserve capacity mix

With higher installed wind capacity, the reserve requirement in Romania is higher in all years and scenarios in both the upward and downward directions. In the downward direction, the share of wind capacity in reserves increases as more wind capacity is installed. Wind substitutes natural gas and nuclear and other RES (PV and hydro) in the downward direction. In the upward direction, the additional reserve capacity needs due to higher wind penetration are mainly covered by natural gas at the beginning of the period and by hydro storage, batteries and DSM in 2040 and in 2050.




Figure 15: Composition of reserve capacities in the different scenarios, MW

4.7 CO₂ emissions

The CO₂ emissions of Romania decreases over time. The difference between wind scenarios varies a lot depending on the modelled years. More wind capacity in the region tends to reduce Romania's CO₂ emissions by around 300 kt in 2030, 800 kt in 2050 comparing the low and high scenarios. By 2040 however the difference between both scenarios' peaks at 2000 kt.




Figure 16: CO₂ emissions in the different scenarios, kt

5 CONCLUDING REMARKS

The overall potential for both onshore and offshore wind in Romania is significant in energetic terms, by far exceeding the current level of overall electricity consumption. A closer look at the regional breakdown of the technical onshore wind potentials and of corresponding wind resources allows for identifying at least five regions within Romania that can be classified as (very) good concerning wind site qualities. That top-five list includes the regions Tulcea, Constanța, Brăila, Galați and Ialomița. The overall technical potential for wind power of all these five regions together is enormous, even with consideration of land use and nature protection constraints it sums up to 48.1 GW or 122.6 TWh, respectively. This is twice as high as the electricity consumption of the whole of Romania at present. Focussing on these areas may allow to better tackle one key barrier to an enhanced wind power uptake: the necessary grid expansion. At present many Romanian stakeholders classify this as the central hurdle for a rapid uptake of this promising carbon-free energy carrier.

Apart from onshore wind, there are even more significant offshore resources applicable in the Black Sea region. Thus, for offshore wind both Bulgaria and Romania have promising sites at hands but generally offshore comes at higher cost compared to onshore. For an offshore wind farm up-front investment cost are currently about 50% to 100% higher in comparison to onshore due to higher cost for the foundations and for grid connection. Thus, this needs to be compensated by better resource qualities.

Taking a closer look at the role of wind power in Romania at present (3.0 GW) and in current energy planning (5.6 GW, according to the 2019 National Energy and Climate Plan of Romania (Republic of Romania, 2019)), we can conclude that there is sufficient room for enhancing the wind uptake in future years. Given the resources at hands, wind power deserves to take a more prominent role in future energy planning in Romania. Care should however be taken in the planning process of a wind farm in order to minimise negative social and environmental impacts. Avoiding negative impacts on biodiversity appears thereby of key relevance since specifically the Danube delta at the Black sea region as well as other parts of the country serve as nature protected habitats for bird's breeding etc.

The assessment of market impacts as well as the brief consideration of economics for wind power confirm the above. Thus, Romania offers promising wind sites at comparatively cheap cost, considering current prices on electricity wholesale markets. The expectable market impacts are generally promising since an enhanced wind uptake may go hand in hand with a decrease of wholesale prices in Romania and it will be beneficial for Romania's combat against climate change, causing a further decline of carbon emissions in future years.

6 REFERENCES

- Bollmeyer C., J. D. Keller, C. Ohlwein, S. Wahl, S. Crewell, P. Friederichs, A. Hense, J. Keune, S. Kneifel, I. Pscheidt, S. Redl, S. Steinke, 2014: Towards a high-resolution regional reanalysis for the European CORDEX domain. Article published in: Quarterly Journal of the Royal Meteorological Society, first published: 28 October 2014. Accessible at <https://doi.org/10.1002/qj.2486>.
- Energy Policy Group, 2020: Romania's Offshore Wind Energy Resources: Natural potential, regulatory framework, and development prospects, November 2020. Accessible at https://enpg.ro/wp-content/uploads/2022/03/EPG_Wind-Offshore-report_Final_Nov-16.pdf
- Eurostat, 2023: SHARES tool on the Share of Renewable Energy Sources in the European Union - Calculation methodologies for the share of renewables in energy consumption, 2023 (online) edition. Accessible at https://ec.europa.eu/eurostat/statistics-explained/index.php?oldid=555286#Share_of_renewable_energy_based_on_Directive_2009.2F28.2FEC_and_Directive_28EU.29_2018.2F2001_28SHARES_tool.29.
- IUCN and UNEP-WCMC, 2020: The World Database on Protected Areas (WDPA) [https://www.protectedplanet.net/en/search-areas?filters%5Bdb_type%5D%5B%5D=wdpa&geo_type=region], [08/2020], Cambridge, UK: UNEP-WCMC. Accessible at: www.protectedplanet.net.
- Republic of Romania, 2019. National Energy and Climate Plan for the Republic of Romania, accessible at https://commission.europa.eu/energy-climate-change-environment/implementation-eu-countries/energy-and-climate-governance-and-reporting/national-energy-and-climate-plans_en#national-energy-and-climate-plans-2021-2030.
- Resch G., Liebmann L., Hirner R., Mezosi A., Szabo L., 2023: Technical report on the Assessment of Wind Potentials in Bulgaria, Hungary, and Romania. A study conducted by AIT and REKK on behalf of the European Climate Foundation. Vienna, Budapest, 2023.
- Rouault E., 2022: GDAL description and library. Remark: GDAL is an open source X/MIT licensed translator library for raster and vector geospatial data formats. Accessible at <https://github.com/rouault/gdal>.
- Schulzweida U., 2019: CDO (Climate Data Observer) user guide. Software description, version 1.9.8, published October 31, 2019. Accessible at <https://zenodo.org/records/3539275>.